



DECLARATION OF PERFORMANCE (DoP)

in accordance with Annex III to Regulation (EU) no. 305/2011
(Construction Products Regulation)

FIRESAFE / FSC
DoP no.: FS/PP/FSC – 30.07.2025

1. Unique identification of the product type:

FIRESAFE / FSC Universal Firestop Collar for Penetration Seals.

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4): See batch number on product packaging or scan the QR code on the packaging for detailed information.

3. Intended use or uses of the construction product in accordance with the applicable harmonised technical specification:

3.1 The intended use of FIRESAFE / FSC is the maintenance of the fire resistance performance of plaster walls, masonry walls and floors for the fireproofing of various pipe penetrations made of plastic, metal and aluminium, composite pipes with and without combustible insulation, electrical cables and flue gas pipe systems. When using FIRESAFE / FSA Firestop Acrylic in combination with FS / FSC, a fire- and smoke-resistant seal is achieved against adjoining rooms as contained in **ETA 25/0232**.

3.2 The use category for the FIRESAFE / FSC system is indoor use, conditions: high ambient humidity, except at temperatures below 0°C, and without exposure to rain or UV (TR 024:2019, type Z₁).

3.3 The provisions contained in the Declaration of Performance are based on an assumed service life of FIRESAFE / FSC of 25 years: provided that all conditions in the manufacturer's data sheet and instructions for packaging, transportation, storage, installation, use and repair have been met. The indications given to the end user cannot be interpreted as a guarantee provided by the manufacturer, but must only be considered as an aid to choosing the right products in relation to the expected financially reasonable service life of the solution.

4. Name, registered trade name or registered trademark and contact address of the manufacturer as required pursuant to Article 11(5):

Firesafe AS
Robsrudskogen 15, 1470 Lørenskog
Postboks 6411 Etterstad, 0605 OSLO
Telephone: +47 22 72 20 20
www.firesafe.no

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):
Not relevant.

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
AVCP System 1.

7. In the case of the Declaration of Performance concerning a construction product covered by a harmonised standard:
Not relevant.

8. In the case of the Declaration of Performance concerning a construction product for which a European Technical Assessment has been issued:

This Declaration of Performance has been prepared in accordance with the guidelines contained in EAD 350454-00-1104.
ETA 25/0232 prepared by UL International BV, Notified Body 2821, Certificate of Performance no. 2821-CPR-0347.

9. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
Reaction to fire	Class E	EN 13501-1
Resistance to fire	ETA 25/0232 Penetration Seals	EN 13501-2
Air permeability	NPD	EN 1026: 2000
Water permeability	NPD	EAD 350454-00-1104, Annex C
Release of hazardous substances	As the supplier, we declare that no hazardous substances are released during installation or use of the product. See safety data sheets.	
Mechanical resistance and stability	NPD	EOTA TR 001: 2003
Resistance to shock/movement	NPD	EOTA TR 001: 2003
Airborne sound insulation	NPD	EN 10140-1,2,4,5/ EN ISO 717-1
Impact sound insulation	NPD	EN 10140-3
Thermal properties	NPD	EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456
Water vapour permeability	NPD	EN ISO 12572, EN 12086, EN ISO 10456
Durability and usability	Z ₁ in accordance with TR 024: 2019	EAD 350454-00-1104, point 2.2.9

NPD = No Performance Determined.

10. The performance of the product identified in points 1 and 2 is in conformity with the performance in point 9.

This Declaration of Performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of Firesafe:

Pål Paulsen

Technical Department – Product Manager, Firestopping Products

FIRESAFE AS

